WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65818
Permit No.
Basin 212

NOTICE OF INTENT NO. 9636

1. OWNER Clark County School Dist.
MAILING ADDRESS 1700 Galleria Bldg. C
Henderson NV

ADDRESS AT WELL LOCATION R. C. White Trans Ctr
4499 S. Arville St.
Las Vegas, NV.

2. LOCATION SE ¼ NW ¼ Sec. 19 T 21 N/S R 61 E Clark County
PERMIT NO. MO-2147 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG MW-5

Material	Water Strata	From	To	Thickness
Silty sand		0	4'	4'
Silty clay		4	7	3'
Caliche		7	10	3
Gravelly sand		10	14	3
Silty sand		14	18	4
Caliche		18	23	5
Sandy clay	▽	23	30	7
Caliche		30	32	2'
Sandy clay		32	37	5'
Clayey sand		37	45	8'
	Total depth			45'

RECEIVED
OCT 19 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8/31, 1992
Date completed 8/31, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4-Inch		Sch 40	0	45

Perforations:
Type perforation Machine slotted
Size perforation 0.020
From 15 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 11 (2' Bent)
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 13 feet to 45 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson (Contractor)
Address 4670 S. Polaris Ave. (Contractor)
Las Vegas NV.
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-2-92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627