SCW-7

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65831
Permit No.
Basin 212

NOTICE OF INTENT NO. 10760

1. OWNER CLARK COUNTY SCHOOL DISTRICT
MAILING ADDRESS 1700 GALLERIA, BLDG C
HENDERSON, NEVADA, 89104

ADDRESS AT WELL LOCATION 4499 S ARVILLE ST
LAS VEGAS, NV

2. LOCATION SE ¼ NW ¼ Sec. 19 T. 21 X S R. 61 E. CLARK County
PERMIT NO. M02292 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	0.5	0.5
FILL		0.5	1.5	1.0
CLAY w/ SAND		1.5	9.5	8.0
CALICHE		9.5	17.5	8.0
CLAY w/ SAND		17.5	30.0	12.5
CLAY w/ SILT		30.0	40.0	10.0

RECEIVED
JUL 26 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6/18, 1993
Date completed 6/18, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	0 Feet	40 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	0.70	SCH 40	0	40

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 0.020
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8'-0"
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 40 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHARD LEBLANC / CONVERSE CONSULTANTS (Contractor)
Address ~~4760~~ 4670 S POLARIS AVE (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed (By driller performing actual drilling on site or contractor)
Date 7-20-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627