WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65873
Permit No.
Basin 212

NOTICE OF INTENT NO. 11024

1. OWNER Union Oil Company of California
MAILING ADDRESS 17700 Castleton Street Ste.500
City of Industry, California 91748

ADDRESS AT WELL LOCATION Unocal 6131
3781 Las Vegas Blvd. South
Las Vegas, Nevada 89109

2. LOCATION SW ¼ SW ¼ Sec. 21 T. 21 ~~N~~/S R. 61 E. Clark County

PERMIT NO. MO-2206 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	0.2	0.2
Gravelly Sand		0.2	5	4.8
Silty Sand		5	14.5	8.5
Clay		14.5	20	5.5
Caliche		20	24	6
Silty Sand		24	28	8
Clay	water	28	37.5	9.5
Caliche	water	37.5	----	----
(completed as MW-3)				

RECEIVED
DEC 16 1992
Div. of Water Resources
Special Office - Las Vegas, NV

Date started October 23, 19 92
Date completed October 23, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 37.5 Feet Depth Cased 37.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
4 Inches	0 Feet	37.5 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	2.04	0.25	0	40

Perforations:
Type perforation Slotted
Size perforation 0.020 inches
From 22 feet to 37 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 18
Placement Method: [ ] Pumped [X] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 21 feet to 37.5 feet

9. WATER LEVEL
Static water level 30.33 feet below land surface
Artesian flow 0 G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kleinfelder (Contractor)
Address 6850 Paradise Road (Contractor)
Las Vegas, Nevada 89119

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1591

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12-9-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627