

OFFICE USE ONLY
 Log No. 65910
 Permit No. _____
 Basin: 108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32666

1. OWNER Doc Giles ADDRESS AT WELL LOCATION 131 Hwy 95 A
Yerington NV. 89447
 MAILING ADDRESS 131 Hwy 95 A
Yerington NV. 89447
 2. LOCATION SE 1/4 SE 1/4 Sec. 96 T. 14 N. R. 25 E. Lyon County
 PERMIT NO. 14-231-14 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RYC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Course Sands		0	16	16
Course Gravels Pea Gravels		16	45	29
Brown Clay		45	87	42
Course Sand and Clay Stratas		87	125	38
Brown Sandy Clay		125	169	44
Course Gravel Zone Carrying Water	XX	169	200	31
T.D. 200'				

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 9/8</u>	<u>13.03</u>	<u>.188</u>	<u>12</u>	<u>200</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 X 3/8
 From 180 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 200 feet
 9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. 30+ P.S.I.
 Water temperature cold °F Quality Good

Date started 2-23, 1997
 Date completed 2-26, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>	<u>45</u>	<u>4 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling
 Address 20 Kit Kat Dr.
Carson City NV. 89706
 Nevada contractor's license number 41775
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael J. Beck
 By driller performing actual drilling on site or contractor
 Date 2-26-97