

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Permit No. 65923
 Permit No. 061
 Notice of Intent No. 26243

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE
 MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

2. LOCATION NE 1/4 NW 1/4 Sec 30 T 36 N S R 50 E EUREKA County
 PERMIT NO. 55150 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Test
 Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
NOTE: CEMENT BASKET ON OD OF 4" PLACED AT 72' DURING CONSTRUCTION.				
POURED 24 BAGS OF 3/8" HOLE PLUG INTO THE WELL UNTIL IT WAS TAGGED AT 50'.				
THEN A 50' NEAT CEMENT SEAL WAS POURED ON TOP OF THE HOLE PLUG.				
BARRICK GOT VERBAL APPROVAL FROM JASON KING AND STEVE WALMSLEY TO POUR HOLE PLUG FROM THE SURFACE DUE TO AREA FAILURE				

8. WELL CONSTRUCTION
 Depth Drilled 430 Feet Depth Cased 398 Feet

HOLE DIAMETER (BIT SIZE)
 From To
8 Inches 17 Feet 430 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	22.36	.250	0	17
4"	PVC	SCH 40	0	46

Perforations:
 Type perforation MILL SLOT
 Size perforation 1/8 X 3
 From 96 feet to 398 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 51

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From feet to feet

9. WATER LEVEL
 Static water level 193 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

Date started MARCH 13, 1997
 Date completed MARCH 13, 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor
 Address 2286 WEST 1500 SOUTH Contractor
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1716

Signed DAVID HAAS *David Haas*
 By driller performing actual drilling on site or contractor

Date 3-13-97