

WHITE—DIVISION OF WATER RESOURCES  
 CANARY—CLIENT'S COPY  
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 65931  
 Permit No. 262  
 Basin. 262

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26239

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLSTRIKE MINE  
 MAILING ADDRESS P.O. BOX 29  
ELKO, NV 89801

2. LOCATION SW 1/4 NE 1/4 Sec 19 T 36 N S R 50 E EUREKA County  
 PERMIT NO. 55141 Parcel No. N/A Subdivision Name N/A  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Municipal  Industrial  
 Irrigation  Monitor  Test  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN & BLACK ROCK		0	40	40
NO CIRCULATION		40	200	160
BROWN & GREY ROCK		200	225	25
BROWN CLAY		225	290	65
GREY CLAY		290	325	35
BLACK/GREY CLAY		325	370	45
BROWN CLAY		370	375	5
BLACK ROCK		375	380	5
GRAY CLAY		380	400	20
BROWN CLAY		400	440	40
GRAVEL/CLAY		440	450	10
BROWN CLAY		450	455	5
GRAVEL/CLAY		455	480	25
GRAY ROCK/CLAY		480	510	30
BROWN ROCK/CLAY		510	540	30
CLAY		540	600	60
BROWN ROCK		600	620	20
GRAY & BROWN ROCK/CLAY		620	660	40
BROWN ROCK/CLAY		660	680	20
GRAY ROCK		680	700	20
GREEN ROCK		700	800	100

8. WELL CONSTRUCTION  
 Depth Drilled 800 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
.17 Inches 0 Feet 20 Feet  
9-7/8 Inches 20 Feet 800 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12-1/4	49.5	.375	0	20
6	17.02	.250	0	120

Perforations:  
 Type perforation LOUVERED  
 Size perforation .125  
 From 120 feet to 800 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 800 feet to 100 feet

9. WATER LEVEL  
 Static water level 194 feet below land surface  
 Artesian flow NONE G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature 60 °F Quality \_\_\_\_\_

Date started FEBRUARY 12, 1997  
 Date completed FEBRUARY 20, 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	619	1 HR
	425 OF DRAWDOWN	
	RECOVERED TO 262 IN 1 HR	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor  
 Address 2286 WEST 1500 SOUTH Contractor  
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2039  
 Signed DENNY ROBBLEE *Denny Robblee*  
 By driller performing actual drilling on site or contractor  
 Date FEBRUARY 20, 1997