

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 65948
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15533

1. OWNER Charles Sumpter ADDRESS AT WELL LOCATION Manse and Julie, Pahrump Nevada 89048
 MAILING ADDRESS Manse and Julie Pahrump, NV 89048

2. LOCATION NE 1/4 NE 1/4 Sec. 7 T 21S N/S R 54E E Nye County
 PERMIT NO. 45-081-01 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	16	16
Light Brown Clay		16	31	15
Brown Calichia		31	48	17
White Clay		48	60	12
Tan Clay	x	60	79	19
Brown Calichia	x	79	88	9
Light Brown Clay	x	88	108	20
Light Brown Calichia	x	108	124	16
Brown Clay	x	124	140	16

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 3/4 inches 0 feet 140 feet
 _____ inches _____ feet _____ feet
 _____ inches _____ feet _____ feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	13	188	0	140

Perforations:
 Type perforation Saw cut 1/8"
 Size perforation .25 x 6
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 6/5/97, 19____
 Date completed 6/6/97, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>na</u>	<u>.50</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
 Signed Larry Strickland
 By driller performing actual drilling on-site or contractor
 Date 6-20-97

