

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 65965
Permit No. 0661
Basin
NOTICE OF INTENT NO. 26256

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801
2. LOCATION NW 1/4 NE 1/4 Sec 19 T 36 N S R 50 E EUREKA County
PERMIT NO. 55141 N/A N/A
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic MINING Irrigation Test
 Municipal Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BLACK & GREY ROCK		0	50	50
BLACK & GREY ROCK /		50		
RED CLAY			120	70
RED ROCK & RED CLAY		120	430	310
GREY & TAN ROCK		430	450	20
GREY & TAN ROCK &		450		
TAN CLAY			490	40
BLACK, GREY & TAN ROCK		490	515	25
GREY, TAN ROCK & TAN CLAY		515	545	30
BLK, TAN & GREY ROCK		545	570	25
TAN CLAY		470	580	10
BLACK, TAN & GREY ROCK		580	605	25
GREY & TAN ROCK		605	725	120
TAN CLAY		725	740	15
TAN & GREY ROCK &		740		
TAN CLAY			850	110

8. WELL CONSTRUCTION
Depth Drilled 850 Feet Depth Cased 840 Feet
HOLE DIAMETER (BIT SIZE)
From To
17-1/2 Inches 0 Feet 20 Feet
9-5/8 Inches 20 Feet 850 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12.75	33.38	.250	0	20
6.50	16.68	.250	+1.5	120

Perforations:
Type perforation LOUVERED
Size perforation 1/8"
From 120 feet to 840 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 850 feet to 100 feet

9. WATER LEVEL
Static water level 154.3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 70 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING
Contractor
Address 2286 WEST 1500 SOUTH
Contractor
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number 0021976
issued by the State Contractor's Board.
Nevada driller's license number issued by the 1939
Division of Water Resources, the on-site driller
Signed KEVIN ELLISON *Kevin Ellison*
By driller performing actual drilling on site or contractor
Date MARCH 27, 1997

Date started MARCH 22 1997
Date completed MARCH 27 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
65	381.7	1 HR	