WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 65993
Permit No
Basin 212

NOTICE OF INTENT NO 15935

1. OWNER Department of Aviation
MAILING ADDRESS P.O. Box 11005
Las Vegas, NV 89111-1005
ADDRESS AT WELL LOCATION 4811 Paradise Road
Las Vegas NV

2. LOCATION S ½ SW ¼ Sec 22 T 21 N/S R 61 E Clark County
PERMIT NO MP-2778 Issued by Water Resources
162-22-401-002 Parcel No.
Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE MW-10: [ ] Domestic [ ] Municipal/Industrial [X] Irrigation [X] Monitor [ ] Test [ ] Stock

5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG MW-10

Material	Water Strata	From	To	Thickness
~~Clayey Silty Sand~~		~~0.5~~	~~0.5~~	~~0.5~~
		~~0.5~~		
Clayey Silty Sand		0	1.0	1.0
Silty Gravel w/ Sand		1.0	3.0	2.0
Gravelly Clayey Silt		3.0	11.0	8.0
Caliche		11.0	12.0	1.0
Gravelly Sand		12.0	16.0	4.0
~~Caliche~~ Sandy Clay		16.0	17.0	1.0
Caliche		17.0	19.0	2.0
Silty Sand		19.0	20.0	1.0
Sand		20.0	24.0	4.0
Silty Sandy Gravel		24.0	30.0	6.0

Date started 5-15 1997
Date completed 5-15 1997

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	30

Perforations:
Type perforation Factory Slot
Size perforation 0.020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-6 / 4-6 bentonite
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 6 feet to 30 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson - Converse Contractor
Address 731 Pilot Road Ste H Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1509
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-23-97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627