WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65997
Permit
Basin 072

NOTICE OF INTENT NO. 36070

1. OWNER Don Nutting
MAILING ADDRESS P.O. Box 1210
Lovelock, NV 89419

ADDRESS AT WELL LOCATION
Nevada 400 Highway
Lovelock, NV 89419

2. LOCATION NW 1/4 NW 1/4 Sec. 33 T 32N N/S R 35 E Pershing County
PERMIT NO. _____ Issued by Water Resources
08-550-01 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [X] Deepen [ ] Replace [ ] Abandon [ ] Recondition [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Municipal/Industrial [ ] Irrigation [ ] Monitor [ ] Test [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Air [X] Rotary [ ] Other [ ] RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay w/gravel		0	83	83
Fractured rock w/clay		83	358	275
Fractured rock w/sand		358	400	42

RECEIVED 97 APR -8 AM 11:05 STATE ENGINEER'S OFFICE

Date started 3/24/97 , 19__
Date completed 3/27/97 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		3 1/2

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 397 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	397	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	397

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 X 3
From 357 feet to 397 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 120 feet below land surface
~~Artesian flow~~ ____ ~~G.P.M.~~ ____ ~~P.S.I.~~
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. Contractor
Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed [signature] By driller performing actual drilling on-site or contractor
Date 4-7-97