

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **15483**

1. OWNER MIKE MEAD ADDRESS AT WELL LOCATION MAIN ST. + FAYLE
 MAILING ADDRESS _____ GOODSPRINGS NV.

2. LOCATION SE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 26 T 24 N OR 58 E CLARK County
 PERMIT NO. 580-638-002+006 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ROCK + GRAVEL		0	20	20
CEMENTED SAND + GRAVEL		20	60	40
WHITE LIME STONE		60	75	15
RED ROCK		75	85	10
WHITE LIME STONE		85	95	10
RED ROCK		95	110	15
WHITE LIME STONE		110	160	50
RED ROCK		160	180	20
WHITE LIME STONE WITH FRACTURES	W.B.	180	215	35

8. WELL CONSTRUCTION
 Depth Drilled 215 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>12 1/4</u>	0	60
<u>9 7/8</u>	60	85
<u>7 7/8</u>	85	215

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.94</u>	<u>.188</u>	<u>0</u>	<u>215</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1/2 INCH BY 3/4 INCH
 From 215 feet to 195 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 172 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 6-4 1997
 Date completed 6-13 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO. Contractor
 Address P.O. Box 3505 Contractor
PAHRUMP NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 40020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Arnie Brown
 By driller performing actual drilling on site or contractor
 Date 6-13-97