

OFFICE USE ONLY
 License No. 66014
 Permit No. 1
 Basin 084
 NOTICE OF INTENT NO. 33894

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER BOEING NORTH AMERICAN, INC. ADDRESS AT WELL LOCATION 2650 Whiskey Springs Road
 MAILING ADDRESS 6633 Canoga Ave Reno, Nevada 89510
Canoga Park, CA. 91303
 2. LOCATION SW 1/4 SW 7 T. 22N N/S R. 22 E. Washoe County
 PERMIT NO. See Letter 4-28-97 077-320-01 B Palomino Valley Unit II 7-2-2-6
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	5	5
Sandy clay & gravels w/some boulder	X	5	34	29
Rusty brown volcanic rock		34	35	1
Weathered brown volcanic rock		35	40	5
Brown volcanic rock		40	57	17
Soft zone (NO WATER)		57	63	6
Brown volcanic rock		63	84	21
Soft zone (NO WATER)		84	85	1
Brown volcanic rock		85	113	28
Brown clay		113	114	1
Soft clay & volcanic rock		114	120	6
Brown volcanic rock		120	130	10
Brown volcanic rock with clay streaks		130	143	13
Purple volcanic rock		143	150	7

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 150 Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	steel	.188	+1	25
6 5/8	PVC	sch 80	25	35

 Steel to PVC adaptor, End Cap, Top Cap Welded
 Perforations: factory sawed slot
 Type perforation
 Size perforation .040 screen PVC
 From 25 feet to 35 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 17 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal @ 17 to 20 feet
 Gravel Packed: Yes No 1/8x1/4 well rock
 From 20 feet to 35 feet

* Note: no water encountered below 35'. Well was cemented back to 35' level. Per Tel con w/ Ingrid, Wayne Drilling. Matt 5-13-97

9. WATER LEVEL
 Static water level 10.3 feet below land surface
 Artesian flow 2 1/2 G.P.M. 2 1/2 P.S.I.
 Water temperature cold °F Quality clear

Date started 4-21-97, 19
 Date completed 4-23-97, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>2 1/2</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller.
 Signed Wayne Drilling
 driller performing actual drilling on site or contractor
 Date April 28, 1997