

OFFICE USE ONLY
 Log No. 66018
 Permit No. 084
 Basis Permitive Area
 NOTICE OF INTENT NO. 33890

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER STANLEY LIVINGSTON HOKE ADDRESS AT WELL LOCATION 2640 Whiskey Springs Road
 MAILING ADDRESS 836 Saltwind Drive St. Helena Island, S.C. 29920 Reno, Nevada 89510
 2. LOCATION NE 1/4 SW 1/4 Sec. 7 T. 22N N/S R. 22 E Washoe County
 PERMIT NO. 077-320-089 Palomino Valley Area 7-222
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Multi-color volcanic gravels w/some clays		0	14	14
Reddish brown volcanic rock		14	22	8
Purple volcanic rock		22	24	2
Rusty brown clay		24	26	2
Reddish brown sandy clay		26	41	15
Reddish brown volcanic rock		41	50	9
Gray volcanic rock		50	121	71
Dark gray volcanic rock fractured (app 1 GPM) X		121	123	2
Gray volcanic rock		123	140	17
Green volcanic rock		140	144	4
Fracture green volcanic rock (app 10 GPM) X		144	178	34
Green volcanic rock		178	194	16
Soft zone (NO WATER)		194	196	2
Green volcanic rock		196	207	11
Brown volcanic rock		207	215	8
Brown volcanic rock fracture (app 40+GPM) X		215	242	27
Brown volcanic rock		242	250	8

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 250 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	250

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 184 feet to 244 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 foot
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 250 feet

9. WATER LEVEL
 Static water level 42 feet below land surface
 Artesian flow _____ G.P.M. 60+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date April 22, 1997

Date started 4-14-97, 19____
 Date completed 4-16-97, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>60+</u>			