

Permits: 63064-5 64265-6  
 63072,4 64268-9  
 63546  
 63708  
 #PCARCC

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT  
 N39.793193 W119.624335 N4027



office use only  
 Log No. 666020  
 Permit No. ....  
 Basin 084

NOTICE OF INTENT NO 34900

Gross Valley Road

1. OWNER **Edwards Hayes**  
 MAILING ADDRESS **26656 Purissima Road**  
**Los Altos Hills, Ca.**

ADDRESS AT WELL LOCATION

*Palomino V. Unit 1 9-2-1-3*

2. Location **NW 1/4 NE 1/4 Sec 9 T 22N R 21E**  
 PERMIT NO. **PARCEL NO. 077-100-12**

**Washoe County**

SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
Coarse brown yellow green white orange white orange vol sands with small sticky tan clay layers.		0	140	140
Red brown vol rock with sticky red clay.		140	305	165
Red green yellow orange white vol red clay.		305	320	15
Sticky red clay with small sand zones.		320	407	87
Sticky red clay with small sand zones		407	590	183
Sticky red clay.		590	605	15
Coarse vol sands traces of red clay.		605	625	20
Sticky red clay.		625	660	35

8. WELL CONSTRUCTION					
Depth Drilled		Depth Cased		HOLE DIAMETER (BIT SIZE)	
From	To	From	To	From	To
	660 feet		660 feet		
12 1/4 inches	0 feet	0 feet	660 feet		
CASING SCHEDULE					
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)	
8 5/8	16.9	188	+1.5	660	
Perforations::					
Type Perforation	factory				
Size perforation	1/8 x 3				
From	220 feet	to	620 feet		
From		to			
From		to			
From		to			
From		to			
From		to			
Surface Seal	<input checked="" type="checkbox"/> YES	No	Seal Type:		
Depth of Seal	58 feet		Neat Cement		
		<input checked="" type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Cement Grout		
		Poured	Concrete Grout		
Gravel Packed:	<input checked="" type="checkbox"/> Yes	No			
From	660 feet	to	58 feet		

9. WATER LEVEL			
Static water level	115 feet	below land surface	
Artesian flow	0 GPM	0 P.S.I.	
Water Temperature	cool	Degrees F	Quality

Date started **4-8 -97**  
 Date completed **4-21 -97**

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)
200+	650		10

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**  
 NV Contractors No. **14170**  
 NV Driller's Lic (on site) **1511**  
 Signed *Steve McKay*  
 By driller performing actual drilling on site or contractor  
 Date **4-28 -97**