WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66027
Permit No.
Basin 212

NOTICE OF INTENT NO. 12127

1. OWNER LAS VEGAS VALLEY WATER DIST.
MAILING ADDRESS 3700 W. CHARLESTON BLVD LAS VEGAS, NV 89153
ADDRESS AT WELL LOCATION SWC LAKE MEAD BLVD & TORREY PINES DR.

2. LOCATION NE ¼ SW ¼ Sec 23 T 20 N/S R 60 E CLARK County
PERMIT NO. MO-2356 Issued by Water Resources | Parcel No. | KONZONE RESERVOIR. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND w/GRAVEL		0	3	3
GRAVELLY SAND		3	6	3
SILTY SAND w/GRAVEL		6	8	2
GRAVELLY CLAY		8	11	3
CLAYEY GRAVEL		11	13	2
SANDY GRAVEL		13	26	13
CEMENTED SAND/GRAV		26	27	1
CLAYEY GRAVEL		27	30	3
SILTY SAND		30	32	2
SANDY CLAY		32	35	3
SANDY CLAY w/ GRAVEL		35	43	8
CEMENTED SAND/GRAV		43	48	5
SILTY SAND		48	50	2
CEMENTED SAND/GRAV		50	53	3
SILTY SAND		53	56	3
SANDY GRAVEL		56	60	4
CEMENTED SAND/GRAV		60	64	4
POORLY GRADED SAND	X	64	68	4
CEMENTED SAND		68	69	1
CLAYEY SAND		69	75	6
GRAVELLY SAND		75	80	5
SANDY GRAVEL		80	84	4
SILTY SAND		84	86	2
SANDY CLAY		86	86.5	0.5
SANDY GRAVEL		86.5	90	3.5
GRAVELLY SAND		90	95	5

Date started DECEMBER 1, 19 93
Date completed DECEMBER 2, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
JAN 11 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 95 Feet Depth Cased 78 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	95 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
3.50	1.4	0.216 Sch 40	0	78

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020"
From 68 feet to 78 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-62½ / 62½-65 BENT.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 65 feet to 78 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DONALD WILSON
Contractor
Address 4630 SOUTH POLARIS
Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller H 1589
Signed
By driller performing actual drilling on site or contractor
Date DECEMBER 20, 1993

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O) 627