WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66048
Permit No.
Basin 212

NOTICE OF INTENT NO. 10105

1. OWNER Silverado Enterprises
MAILING ADDRESS 5620-30 W. Charleston Blvd Las Vegas, NV 89107
ADDRESS AT WELL LOCATION 5620 - 5630 W. Charleston Blvd

2. LOCATION SE ¼ SW ¼ Sec. 36 T 20 ☒/S R 60 E Clark County
PERMIT NO. MO-2520 (Issued by Water Resources) 138-36-408-003 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thickness
Fill - Asphalt over base	N	0	2	2
SANDY CLAY - brn	N	2	9	7
SILTY CLAY - brn	N	9	12	3
SILTY SAND - brn	N	12	17	5
SAND/CLAY layers	N	17	24	7
SANDY GRAVEL	N	24	32	8
CALICHE	N	32	34	2
SANDY CLAY	N	34	40	6
CALICHE	N	40	43	3
SILTY SAND	N	43	50	7
SANDY CLAY - w/gravel red brn	Y	50	66	16

Date started Dec 5, 1994
Date completed Dec 5, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 66 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	66 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	sch 40	0	65

Perforations:
Type perforation slotted screen
Size perforation 0.01"
From 50 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 48
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 48 feet to 66 feet

9. WATER LEVEL
Static water level 53.35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tim Aren c/o WTI (Contractor)
Address 3611 W. Tompkins Ave (Contractor)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board -
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed (by driller performing actual drilling on site or contractor)
Date 12-6-94

(Rev. 3.91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627