

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5660

PRINT OR TYPE ONLY

1. OWNER Las Vegas Paving Corp.
MAILING ADDRESS 1770 Industrial Road
Las Vegas, NV 89102

ADDRESS AT WELL LOCATION 3401 N. 5th Street
North Las Vegas, NV

2. LOCATION SE 1/4 SE 1/4 Sec 10 T. 20 N/S R. 61 E Clark

County

PERMIT NO. Issued by Water Resources

Parcel No.

Subdivision Name

3. MW-2 TYPE OF WORK
New Well Recondition Deepen Other
4. Domestic Municipal Industrial Stock Other
5. TYPE WELL
Cable Rotary

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------|--------------|------|------|------------|
| ASPHALT CONCRETE | | 0 | 0.5 | 0.5 |
| A.C. BASE | | 0.5 | 1.0 | 0.5 |
| SANDY CLAY | | 1.0 | 10.0 | 9.0 |
| CALLICHE | | 10.0 | 12.0 | 2.0 |
| SILTY CLAY | | 12.0 | 18.0 | 6.0 |
| CALLICHE | | 18.0 | 22.0 | 4.0 |
| SILTY CLAY | | 22.0 | 23.5 | 1.5 |
| CALLICHE | | 23.5 | 24.0 | 0.5 |
| SILTY CLAY | | 24.0 | 26.0 | 2.0 |
| CALLICHE | | 26.0 | 26.5 | 0.5 |
| SILTY CLAY | | 26.5 | 29.0 | 2.5 |
| CALLICHE | | 29.0 | 30.0 | 1.0 |
| SILTY CLAY | | 30.0 | 45.0 | 15.0 |
| CLAYEY SAND | | 45.0 | 53.0 | 8.0 |
| SILTY CLAY | | 53.0 | 62.0 | 9.0 |
| SAND and GRAVEL | | 62.0 | 76.5 | 14.5 |

RECEIVED

JAN 18 1991

Water Resources
District Office - Las Vegas, NV

Date started December 6, 1990
Date completed December 6, 1990.

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 2 inches Total depth 76.5 feet

Casing record PVC Schedule 40
Weight per foot 0.7 lbs. Thickness
Diameter 2 inches From 0 feet To 30 7/8 feet

Surface seal: Yes No Type Cement/Bentonite
Depth of seal 50-52 feet
Gravel packed: Yes No
Gravel packed from 52 feet to 76.5 feet

Perforations: Factory slot PVC
Type perforation 0.02 inch
Size perforation 56.5 feet to 71.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60.0 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kleinfelder, Inc.
Contractor
Address 6850 S. Paradise Rd. Las Vegas, NV
Contractor
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1591
Signed [Signature]
By driller performing actual drilling on site or contractor