

OFFICE USE ONLY
 Log No. 66071
 Permit No. _____
 Base _____
 NOTICE OF INTENT NO. 33918

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER MARCIA MURRAY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5645 Mt. Rose Hwy. 5645 Melarky Way
Reno, Nevada 89511 Reno, Nevada 89511
 2. LOCATION NW 1/4 SE 1/4 Sec. 26 T. 18N N/S R. 19 E. Washoe County
 PERMIT NO. _____ Issued by Water Resources Parcel No. 150-250-16 Subdivision Name Mt. Rose Hwy. Area

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING:				
Fill (sand)		242	245	3
Bottom of 8" casing at 245 feet				
Sandy clay with gravels		245	251	6
Sand & gravel	X	251	260	9
Sandy clay with gravels and boulders		260	306	46
Sand & gravels	X	306	310	4
Cemented boulder & gravel		310	316	6

8. WELL CONSTRUCTION
 Depth Drilled 316 Feet Depth Cased 316 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7 1/2 Inches 242 Feet 316 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	316

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 251 feet to 271 feet
 From 291 feet to 311 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal deepening
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 245 feet to 316 feet

Date started 5-13-97, 19_____
 Date completed 5-14-97, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
33		

9. WATER LEVEL
 Static water level 242 feet below land surface
 Artesian flow _____ G.P.M. 33 P.S.I.
 Water temperature cold °F Quality clear
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P. O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date May 19, 1997