WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 66076
Permit No.
Basin 212

NOTICE OF INTENT NO. 13220

1. OWNER Sealor
MAILING ADDRESS 3021 S Valley View dr LV, NV 89102
ADDRESS AT WELL LOCATION 2405 N. Belmont

2. LOCATION SE ¼ SW ¼ Sec. 13 T. 20 N/S R. 61 E. Clark County
PERMIT NO. MO-2443 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| clay w/ all small gravels | | 0 | 30 | |

RECEIVED
NOV 01 1994
Div. of Water Resources
Branch Office · Las Vegas, NV

Date started 7-22, 19 94
Date completed 7-22, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | PVC | SCH 40 | 0 | 10 |
| | | | | |
| | | | | |

Perforations:
Type perforation Slotted screen
Size perforation .020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 8
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 9 feet to 30 feet

9. WATER LEVEL
Static water level 21 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Weber Environmental (Contractor)
Address 4301 S. Valley View (Contractor)
LV, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0035639
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1910
Signed (By driller performing actual drilling on site or contractor)
Date 10-21-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627