WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66093
Permit No.
Basin 212

NOTICE OF INTENT NO. 13063

1. OWNER LAS VEGAS VALLEY WATER DIST.
MAILING ADDRESS 3700 W. CHARLESTON LAS VEGAS NV 89153
ADDRESS AT WELL LOCATION AREA TECHNICAL TRADE CENTER, 444 W. BROOKS AVENUE NORTH LAS VEGAS NV

2. LOCATION NE ¼ NW ¼ Sec. 15 T. 20 N/S R. 61 E. CLARK County
PERMIT NO. MD-2377 Issued by Water Resources
100-930-003 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-ATC-1
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	2	2
SILTY SAND		2	3	1
SANDY SILT		3	6	3
SILTY SAND		6	8	2
CLAY		8	13	5
SANDY SILT		13	14	1
CLAY		14	16	2
CALICHE		16	16.5	0.5
GRAVELLY CLAY		16.5	18	1.5
SILTY SAND		18	19	1
CLAY		19	32	13
POORLY GRADED SAND		32	34	2
CLAYEY SAND		34	35	1
CLAY		35	41	6
SILTY SAND		41	42	1
SANDY SILT		42	45	3
SANDY CLAY		45	53	8
SILTY SAND		53	55	2
CLAYEY SAND		55	58.5	3.5
SANDY CLAY		58.5	62	3.5
SILTY SAND		62	63	1
SANDY CLAY		63	66	3
SILTY SAND		66	70	4
SANDY CLAY		70	75	5
POORLY GRADED SAND		75	80	5

Date started MARCH 3, 1994
Date completed MARCH 3, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
MAR 10 1994
Div. of Water Resources
Interim Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 72 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	74 Feet
5 Inches	74 Feet	80 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
3.5	1.4	0.216	0	72

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 67 feet to 72 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-60'/60-63' BENT.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 63 feet to 72 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON
Contractor
Address 4670 So. POLARIS AVE
Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed
By driller performing actual drilling on site or contractor
Date MARCH 7, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627