STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 66096
Permit No.
Basin 088
NOTICE OF INTENT NO 34898

1. OWNER **Richard Riley** ADDRESS AT WELL LOCATION **8 Jeffrey Pine Rd**
MAILING ADDRESS **715 N. Why 395**
Reno NV

2. Location **SW** 1/4 **NW** 1/4 Sec **23** T **17 N** R **19E** **Washoe** County
PERMIT NO. PARCEL NO. **046-060-16** SUBDIVISION NAME

3. WORK PERFORMED
X New Well | Replace | Recondition
Deepen | Abandon | Other

4. PROPOSED USE
X Domestic | Irrigation | Test
Municipal/Industrial | Monitor | Stock

5. WELL TYPE
Cable | X Rotary | RVC
X Air | Other | Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
				0
Darkl brown sand with cobbles & boulders.		0	8	8
				0
Blue green yellow white DG.		8	120	112
				0
Blue white granite boulders.		120	128	8
				0
Green yellow white DG.		128	271	143
				0
Blue green granite (hard).		271	600	329
				0
				0
Bottom of hole full of native material.				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0

97 APR 25 AM 10:59

8. WELL CONSTRUCTION
Depth Drilled **600** feet Depth Cased **575** feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	inches	0	feet	50	feet
8 5/8	inches	50	feet	280	feet
6 1/8	inches	280	feet	600	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet
6 5/8	12.94	188	+1.5	280
5"	6.56	188	235	575

Perforations::
Type Perforation **factory**
Size perforation **1/8 x 3**
From **575** feet to **535** feet
From **475** feet to **455** feet
From **255** feet to **235** feet
From feet to feet
From feet to feet

Surface Seal X YES No
Depth of Seal **58** feet
Pumped
X Poured
Gravel Packed: X Yes No
From **58** feet to **280** feet

Seal Type:
Neat Cement
Cement Grout
X Concrete Grout

9 WATER LEVEL
Static water level **235** feet below land surface
Artesian flow **0** GPM **0** P.S.I.
Water Temperature **cool** Degrees F Quality

Date started **3-2** -97
Date completed **3-14** -97

7. WELL TEST DATA
TEST METHOD: Bailer Pump X Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)
40	115	3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **1511**
Signed
By driller performing actual drilling on site or contractor
Date **3-18-97**