WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66115
Permit No.
Basin 212

NOTICE OF INTENT NO. 12114

1. OWNER NEVADA PARTNERS
MAILING ADDRESS 608 SOUTH 8th ST
LAS VEGAS NV 89101

ADDRESS AT WELL LOCATION NORTH OF LAKE MEAD BLVD APPROX 140' EAST OF REVERE ST.

2. LOCATION SW ¼ NW ¼ Sec. 22 T. 20 N/S R. 61 E. CLARK County
PERMIT NO. M0-2339 (Issued by Water Resources) 139-22-201-004 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SILTY SAND | | 0 | 2 | 2 |
| SANDY CLAY | | 2 | 30 | 28 |

TEMPORARY MONITOR WELL INSTALLED. WELL ABANDONED ON OCTOBER 4, 1993 BY PULLING CASING AND GROUTING BOREHOLE WITH CEMENT/BENTONITE SLURRY

Date started SEPTEMBER 30, 1993
Date completed SEPTEMBER 30, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8 Inches | | 0 Feet | 30 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | 0.64 | 0.154 | 0 | 25 |
| | | | | |

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☒ No
Depth of Seal 7-9' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 9 feet to 30 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON
Address 4670 SO POLARIS (Contractor)
LAS VEGAS NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1589
Signed (By driller performing actual drilling on site or contractor)
Date 11-1-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627