WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66117
Permit No.
Basin 212

NOTICE OF INTENT NO. 16900

1. OWNER Triton Environmental Services
MAILING ADDRESS 4760 E. So. Temple #236 Salt Lake City, UT 84111
ADDRESS AT WELL LOCATION 1659 N. Main St. North Las Vegas, Nevada 89030

2. LOCATION SE ¼ SE ¼ Sec. 22 T. 20 N(S) R. 61 E. Clark County
~~PERMIT~~ Water NO. MO-2598 Issued by Water Resources
139-22-812-001 Parcel No.
Laurel West Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	2"	2"
Type II (Brown)		2"	1'	8"
Asphalt		1'	1'2"	2"
Native Brown Silty Sand		1'2"	6'	4'10"
Brown Pea Gravel		6'	7'	1'
Dark Brown silty clay	15½	7'	26'	19'
MW-2				

RECEIVED
FEB 20 1996
DCNR/DWR
LAS VEGAS OFFICE

Date started February 9, 1996
Date completed February 9, 1996

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 26 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	26 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2-375	0.70	Schedule 40	0	25

Perforations:
Type perforation Slotted Screen
Size perforation 0.020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
~~Gravel~~ Sand Packed: ☒ Yes ☐ No
From 8 feet to 26 feet

9. WATER LEVEL
Static water level 15½ feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality ok

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GES Contractor
Address 7560 West Sahara Suite 101 Contractor
Las Vegas, Nevada 89117
Nevada contractor's license number issued by the State Contractor's Board Exempted (Engineer)
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1986
Signed Alex Jones
By driller performing actual drilling on site or contractor
Date February 19, 1996

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627