WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66125
Permit No.
Basin 083

NOTICE OF INTENT NO. 26394

1. OWNER B. DELHAGAN / S. LEVAC
MAILING ADDRESS 21760 CLEMONS RD. VIRGINIA CITY, NV.
ADDRESS AT WELL LOCATION 21760 CLEMONS RD VIRGINIA CITY, NV.

2. LOCATION NE ¼ ~~NW~~ ¼ Sec. ~~15~~ 5 T. 17N N/S R. 21E E. STOREY County
PERMIT NO. 4045 Issued by Water Resources | LOT 61 BLOCK-M Parcel No. | VIRGINIA CITY HIGHLANDS Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY, COBBLES, DE-COMPOSED GRANITE		0	100	100
DG-HARD		100	112	12
GRANITE · GRAY · HARD.		112	160	48
GRANITIC-BROKEN-MED. HARD, GREEN	✓	160	200	40

Date started 5-2, 1995
Date completed 5-4, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
BAIL	15	—	4 HRS.

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	0 Feet	140 Feet
8 5/8" Inches	140 Feet	200 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2'	200

Perforations:
Type perforation MECHANICAL SLOT
Size perforation 3/32 x 1 1/2
From 160 feet to 200 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55' feet to ____ feet

9. WATER LEVEL
Static water level ± 60' feet below land surface
Artesian flow —0— G.P.M. —0— P.S.I.
Water temperature — °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WM BLAINE WELL DRLG & PUMP CO. Contractor
Address 2537 LARY CIRCLE Contractor
CARSON CITY, NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 010950
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 174
Signed ____ By driller performing actual drilling on site or contractor
Date 5/4/95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627