

OFFICE USE ONLY
 Log No. 66131
 Permit No. 212
 Basin. 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12121

1. OWNER SUN EXPRESS CO BROADBENT ASSN ADDRESS AT WELL LOCATION 1562 N. EASTERN AVE, LAS VEGAS, NV 89101
 MAILING ADDRESS 833 NEVADA HWY BOULDER CITY, NV 89005
 2. LOCATION NW 1/4 NW 25 T. 20 N. R. 61 E. CLARK County
 PERMIT NO. MO-2316 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	2	2
SILTY SAND		2	5	3
SILTY CLAY		5	15	10
CLAYEY SAND		15	30	15

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.154</u>	<u>0</u>	<u>30</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 0.020
 From 10 feet to 30 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-6/6-8' BENTONITE Neat Cement Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 8 feet to 30 feet

RECEIVED
 NOV 16 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started OCTOBER 18, 1993
 Date completed OCTOBER 18, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMAS HIGHT Contractor
 Address 41670 SO. POLARIS AVE LAS VEGAS NV 89103 Contractor
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources the on-site driller M1869
 Signed Tom Hight
 By driller performing actual drilling on site or contractor
 Date 11-11-93