

*in Book*

OFFICE USE ONLY  
 Log No. 66161  
 Permit No. 212  
 Basin. 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13212

1. OWNER HWA ADDRESS AT WELL LOCATION N DOT N. CO YARD  
 MAILING ADDRESS 4170 S DELTA AVE  
LV NV 89103  
 2. LOCATION 1/4 NW 1/4 Sec. 27 T. 20 N. R. 61 E. Clark County  
 PERMIT NO. MO-2463 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Tuber

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>CLAY</u>		<u>0</u>	<u>5</u>	
<u>CLAY</u>		<u>5</u>	<u>7</u>	
<u>CLAY WITH SANDS</u>		<u>7</u>	<u>12</u>	
<u>CLAY</u>		<u>12</u>	<u>25</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 25 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>PVC</u>	<u>SC1140</u>	<u>0</u>	<u>10</u>

Perforations:  
 Type perforation slotted screen  
 Size perforation 1.022  
 From 10 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 8  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 9 feet to 25 feet

9. WATER LEVEL  
 Static water level 64 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

RECEIVED  
 SEP 15 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 7-6 1994  
 Date completed 7-6 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wozniak Environmental Contractor  
 Address 4301 S. Valley View H21 Contractor  
LV NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 0035639  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 11910  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9-8-94