WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66172
Permit No.
Basin 212

NOTICE OF INTENT NO. 11169

1. OWNER Arco #1878
MAILING ADDRESS C/o Broadbent & Assoc. 833 Nevada Hwy B.C.
ADDRESS AT WELL LOCATION Arco #1878 Inter. of Washington & Rancho. Las Vegas, Nev.

2. LOCATION NE ¼ SW ¼ Sec. 29 T. 20 N/S R. 61 E. Clark County
PERMIT NO. M02168 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy silt w/fine & coarse gravel		0	6.5	6.5
Silty clay w/fine & coarse gravel		6.5	10	3.5
Caliche		10	14.5	4.5
Silty clay		14.5	23	8.5
Caliche		23	25	2.
T.D = 25'				

Date started 7-1, 1992.
Date completed 7-1, 1992.

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
AUG 13 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 22 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	25 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2 lbs	Sch. 40	0	22

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 5 feet to 22 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-3 / 1-3 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 3 feet to 22 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson. (Contractor)
Address 4670 S. Polaris Ave. (Contractor)
Las Vegas, Nevada 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed (By driller performing actual drilling on site or contractor)
Date 8.13.92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627