WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66185
Permit No.
Basin 212

NOTICE OF INTENT NO. 15539

1. OWNER Leonard and Alice Rodowick
MAILING ADDRESS 4081 E. England
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
4081 E England Pahrump, Nevada 89048

2. LOCATION SW 1/4 SW 1/4 Sec. 32 T 20S N/S R 54E E Nye County
PERMIT NO. _____ Issued by Water Resources | 27-471-27 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	16	16
Grey Calache		16	18	2
Grey Clay		18	28	10
Brown Calache		28	44	16
Brown Clay		44	60	16
Grey Gravel		60	63	3
Light Brown Clay		63	80	17
Grey Clay		80	99	19
Grey Clay Gravel	x	99	108	9
Grey Clay	x	108	124	16
Brown Clay	x	124	140	16
Light Grey Calache	x	140	152	12
Brown Clay	x	152	160	8

JUN 26 1997

Date started 6/23/97, 19__
Date completed 6/24/97, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	na	.50

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 3/4	Inches	0 Feet	160 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	13	188	0	160

Perforations:
Type perforation Saw-cut 1/8"
Size perforation .25 x 6
From 115 feet to 160 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 160 feet

9. WATER LEVEL

Static water level 100 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc.
Contractor
Address 2301 Winery Road, Suite 2
Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025

Signed Larry Strickland
By driller performing actual drilling on-site or contractor

Date June 25, 1997