



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36426

1. OWNER Norbert Walter ADDRESS AT WELL LOCATION EAST SIDE OF
 MAILING ADDRESS P.O. Box 739 S.R. 278 1/2 MILES NORTH OF Jct.
EUREKA NV S.R. 278 & HWY. 50

2. LOCATION NW 1/4 NW 1/4 Sec. 28 T 20 N R 53 E Eureka County
 PERMIT NO. Parcel A 07370-06

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Caliche		2	5	3
Clay sand		5	7	2
Cemented gravel		7	142	135
gravel clay	x	142	149	7
pebbled gravel		149	162	13
River boulders		162	168	6
Cemented gravel		168	222	54
gravel sand	x	222	232	10
Cemented Gravel		232	243	11
gravel sand	x	243	256	13
Cemented Gravel		256	260	4

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet
0 Feet 260 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>260</u>

Perforations:
 Type perforation Full slot
 Size perforation _____
 From _____ feet to _____ feet
 From 230 feet to 250 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 260 feet

9. WATER LEVEL
 Static water level 187 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>301</u>	<u>0</u>	<u>2</u>

Date started May 9 1997
 Date completed May 12 1997

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling & Pump Contractor
 Address P.O. Box 10 Contractor
Eureka NV
 Nevada contractor's license number 0038169
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
 Signed Shan Bennett
 By driller performing actual drilling on site or contractor
 Date May 12 - 97