WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66199
Permit No.
Basin 153

NOTICE OF INTENT NO. [illegible]

1. OWNER Wayne Robinson
MAILING ADDRESS P.O. Box 287
Eureka NV

ADDRESS AT WELL LOCATION Property located on S.R. 278, 1½ mi. N. of Jct. Hwy 50 & S.R. 278 - East side.

2. LOCATION NE ¼ SE ¼ Sec 28 T 20 N S R 53 E Eureka County
PERMIT NO. Issued by Water Resources
7-370-07 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Caliche		2	5	3
Clay sand		5	7	2
Cemented gravel		7	142	135
gravel clay	x	142	149	7
Cemented gravel		149	162	13
River Boulders		162	168	6
Cemented gravel		168	242	74
gravel sand	x	242	267	25
Clay		267	271	4
gravel sand	x	271	278	7
Cemented Gravel		278	280	2

Date started May 5, 19 97
Date completed May 8, 19 97

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
307	0	2

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	280 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	0	280

Perforations:
Type perforation Fac
Size perforation
From 220 feet to 240 feet
From 260 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 280 feet

9. WATER LEVEL
Static water level 93 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA Drilling & Pump Contractor
Address P.O. Box 10 Contractor
Elko NV
Nevada contractor's license number issued by the State Contractor's Board 0038169
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
Signed Shane Bennett
By driller performing actual drilling on site or contractor
Date May - 8 - 97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627