

OFFICE USE ONLY
 Log No. 66214
 Permit No. 00034A
 Basin 173

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24568

1. OWNER Mineral Ridge Resources, Inc. ADDRESS AT WELL LOCATION same
 MAILING ADDRESS P. O. Box 67
Silver Peak, NV 89047

2. LOCATION NE 1/4 NW 1/4 Sec. 32 T 1 N39 E Esmeralda County
 PERMIT NO. 60034A Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE Mining
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden gravel		0	130	130
Green to olive green siltstone, mudstone and clay		130	640	510
Alaskite (oxidized) (weathered at unconformity)		640	720	80
Alaskite (weakly fractured)		720	840	120
Calcarous calc. silicate (Wyman Fm.)		840	960	120
Interlayered Alaskite & calcarous calc-silicate		960	1115	155
Diabase dike		1115	1125	10
Calcarous calc-silicate		1125	1195	70
Fault zone		1195	1215	20
Alaskite and calcarous calc-silicate (Wyman fm.)		1215	1225	10

8. WELL CONSTRUCTION
 Depth Drilled 1225 Feet Depth Cased 1070 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
6 Inches 50 Feet 1225 Feet
 Casing Schedule

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH80	+2	1070

 Perforations: Drilled hole
 Type perforation 1/4 hole every 3'
 Size perforation 850 holes
 From 1070 feet to 850 feet
 From 850 feet to +2 blank feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 1070 feet to 0 feet

94 OCT 20 P 1 13
 STATE ENGINEERS

RECEIVED

OCT 27 1994

STATE ENGINEERS

Date started 10-5 1994
 Date completed 10-7 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	10		2 min.
	40		2 min.
	40-45		2 min.

9. WATER LEVEL
 Static water level 818 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EKLUND DRILLING COMPANY, INC. Contractor
 Address P. O. Box 2786 Contractor
Elko, NV 89803
 Nevada contractor's license number 0030823
 issued by the State Contractor's Board
 Nevada driller's license number issued by the M-1819
 Division of Water Resources, the on-site driller
 Signed Greg Secrest
 By driller performing actual drilling on site or contractor
 Date 10-17-94