

**WELL DRILLER'S REPORT**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14442

1. OWNER LAS VEGAS VALLEY WATER DIST  
 MAILING ADDRESS: 1001 SO. HAWLEY NEW BLVD  
LAS VEGAS, NV 89153

ADDRESS AT WELL LOCATION: WELL FIELD  
2 WOOD MAIN

2. LOCATION SE 1/4 NE 1/4 Sec 31 T 80  
MD-2601 Parcel No. 139-31-702-001

NR 61 E CLARK County

Issued by Water Resources Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4.  Domestic  Municipal/Industrial  
 Irrigation  Test  Stock  
 Monitor  Air  Other AUGER

5. WELL TYPE  
 Cable  Rotary  PVC  
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAVELLY SAND		0	4	4
CEMENTED SAND/GRAVEL		4	5	1
SILTY SAND w/ GRAVEL		5	6	1
SANDY GRAVEL		6	10	4
SILTY GRAVEL		10	11	1
SANDY CLAY		11	15	4
SILTY CLAY		15	16	1
CLAYE		16	18	2
SILTY SAND		18	19	1
SILTY CLAY		19	21	2
SANDY CLAY		21	30	9

8. WELL CONSTRUCTION

Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

From 8 Inches To 30 Feet  
 From 0 Feet To 30 Feet  
 From 0 Feet To 30 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	30

Perforations:  
 Type perforation FA9004 510T  
 Size perforation 0.020 feet to 30 feet

From 5 feet to 30 feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Depth of Seal 0-1'-1-3' BEAUTONITE


Placement Method:  Pumped  Poured

9. WATER LEVEL

Static water level: \_\_\_\_\_ feet below land surface

Artesian flow: \_\_\_\_\_ G.P.M. P.S.I.

Water temperature: \_\_\_\_\_ °F Quality \_\_\_\_\_



10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the reports true to the best of my knowledge.

Name THOMAS HIGHT Contractor

Address: 41670 SO. HAWLEY'S AVE Contractor 89103  
LAS VEGAS NV

Nevada contractor's license number \_\_\_\_\_  
 Issued by the State Contractor's Board \_\_\_\_\_

Nevada driller's license number issued by the \_\_\_\_\_  
 Division of Water Resources, the on-site driller \_\_\_\_\_  
M1869

Signed Thomas Hight  
 By driller performing actual drilling on site of contractor \_\_\_\_\_

Date: 7-24-95

7. TEST METHOD:  Bailor  Pump  Air Lift  
 G.P.M. (Feet Below Static) Time (Hours)

Date started July 13 1995  
 Date completed July 14 1995

WELL TEST DATA

TEST METHOD:	Bailor	Pump	Air Lift
G.P.M.			
(Feet Below Static)			
Time (Hours)			