

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 660247
 Permit No. 212
 Basin 212

NOTICE OF INTENT NO. 14442
 LINDY MAN WELL

1. OWNER LAS VEGAS LAUREY WATER DIST
 MAILING ADDRESS 1001 S. LAUREY VIEW BLVD
LAS VEGAS NV 89153

ADDRESS AT WELL LOCATION CLARK

2. LOCATION SE 1/4 NE 1/4 Sec 31 T 20 N 01 E
MO-2601 139-31-702-001

County CLARK

3. WORK PERFORMED
 New Well
 Replace
 Deepen
 Abandon
 Recondition
 Other

4. Domestic
 Municipal/Industrial
 Monitor
 Stock

5. WELL TYPE
 Cable
 Rotary
 Auger
 Test
 Air
 Other

Subdivision Name

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILTY SAND		0	3	3
CEMENTED SAND/GRAVEL		3	6	3
SILTY SAND		6	8	2
CEMENTED SAND/GRAVEL		8	10	2
CLAYEY SAND		10	11	1
SILTY SAND		11	13	2
CLAYEY SAND		13	15	2
SILTY SAND		15	18	3
CLAYEY SAND		18	20	2
SILTY CLAY		20	30	10



8. WELL CONSTRUCTION
 Depth Drilled: 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 30 Feet
 Inches: 8 Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>1.9</u>	<u>0.237</u>	<u>0</u>	<u>30</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 0.020
 From 0 feet to 30 feet
 From 0 feet to 0 feet
 From 0 feet to 0 feet
 From 0 feet to 0 feet

Surface Seal: Yes No
 Depth of Seal 0-1-1-3' BENTONITE
 Placement Method: Pumped Concrete GROUT
 Poured
 Gravel Packed: Yes No
 From 3 feet to 30 feet

9. WATER LEVEL
 Static water level: _____ feet below land surface
 Artesian flow: _____ G.P.M. P.S.I.
 Water temperature: _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMAS HIGH
 Address 41670 SO. HARRIS AVE
LAS VEGAS NV 89103

Name of Contractor
 Nevada contractor's license number
 Issued by the State Contractor's Board
 Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller
191869

Signed Thomas High
 By driller performing actual drilling of site or contractor
 Date 7-24-95

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)

Date started July 13 1995
 Date completed July 14 1995