

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 166289
 Permit No. 212
 Basin

NOTICE OF INTENT NO. 14438

1. OWNER TEXACO 96 BROADBENT AVE ADDRESS AT WELL LOCATION 1500 WEST County CLARK
 MAILING ADDRESS 833 NEVADA HWY 51E 4 CHARLESTON BLD
 BOULDER CITY NV 89005

2. LOCATION SE 1/4 SW 1/4 Sec 33 T 20 NR L 61 E Subdivision Name CLARK
 PERMIT NO. NO-2592 Issued by Water Resources 162-02-110-009 Parcel No. 162-02-110-009

3. WORK PERFORMED
 New Well Replace Recondition Domestic Municipal/Industrial
 Deepen Abandon Other

PROPOSED USE MU-15 WELL TYPE WELL
 Irrigation Test Cable Rotary RVC
 Monitor Stock Air Other ALICE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DUCKETE/FILL</u>		<u>0</u>	<u>2.5</u>	<u>2.5</u>
<u>CLAYEY SILT</u>		<u>2.5</u>	<u>6</u>	<u>3.5</u>
<u>SILTY SAND</u>		<u>6</u>	<u>11</u>	<u>5</u>
<u>CLAYEY SILT</u>		<u>11</u>	<u>12</u>	<u>1</u>
<u>SILTY SAND</u>		<u>12</u>	<u>13.5</u>	<u>1.5</u>
<u>CLAYEY GRAVEL</u>		<u>13.5</u>	<u>23.5</u>	<u>10</u>
<u>CLAY</u>		<u>23.5</u>	<u>30</u>	<u>6.5</u>

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
8 Inches From 0 To 30 Feet
8 Inches From 0 To 30 Feet
 Inches From 0 To 30 Feet
 Inches From 0 To 30 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>1.9</u>	<u>0.238</u>	<u>0</u>	<u>30</u>

Perforations: Type perforation FACTORY SUDT
 Size perforation 0.020
 From 5 feet to 30 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-1 1/2' / 1 1/2' - 3 1/2' BENTONITE Neat Cement
 Placement Method: Pumped Cement GROUT
 Poured Concrete GROUT


Gravel Packed: Yes No
 From 3.5 feet to 30 feet

9. WATER LEVEL
 Static water level feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMAS HIGH Contractor
 Address 4670 So. TOULARS AVE
HAS LEGAS Contractor 89103

Nevada contractor's license number issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 14-1869
 Signed Thomas High By driller performing actual drilling or by contractor
 Date 7-24-95



Date started JUNE 27 1995
 Date completed JUNE 27 1995

7. WELL TEST DATA
 TEST METHOD: Bailor Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)

TEST METHOD:	Bailor	Pump	Air Lift
G.P.M.			
Draw Down (Feet Below Static)			
Time (Hours)			