WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66353
Permit No.
Basin

NOTICE OF INTENT NO. 4715

1. OWNER U.S. Air Force
MAILING ADDRESS
ADDRESS AT WELL LOCATION Indian Springs AFAF, Indian Springs, Nevada

2. LOCATION NW ¼ NE ¼ Sec 8 T 16S N(S) R 56 (E) Clark County
PERMIT NO. MO 2239 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand w/Gravel		0	25	
Silty Sand w/Gravel		25	37	
Sandy Clay w/Gravel		37	50	
Clayey Sand		50	57	
Silty Sand w/Gravel	58.4	57	65	
Clayey Sand w/Gravel		65	70	
Clayey Sand		70	76	
Hit water 58.4				
Sounded Hole water at 55.4				
Pulled well casing and Filled Hole with Cement Grout mix (3% Bentonite to cement)				

Date started 2/6/93, 19
Date completed 2/17/93, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
68 gal	1 gpm	0	2½ hrs

RECEIVED
FEB 19 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 76 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	76 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½"		Sch-40	0	75

Perforations:
Type perforation Sch 40 PVC
Size perforation .020
From 45 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 40.9
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 42.9 feet to 76.0 feet

9. WATER LEVEL
Static water level 55.4 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name U.S. Bureau of Reclamation
Contractor
Address Arizona Project Office
P.O. Box 9980
Contractor
Phoenix, AZ 85068
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller FP1526
Signed
By driller performing actual drilling on site or contractor
Date 2/18/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627