

Well #3

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66378
Permit No. 21A
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 9732

1. OWNER Valley Hospital/Pepper Jaynes
MAILING ADDRESS

ADDRESS AT WELL LOCATION
Valley Hospital

2. LOCATION NW 1/4 SW 1/4 Sec. 33 T 20 N/S R 61 E Clark
PERMIT NO. DM1002

Parcel No. Subdivision Name County

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other dewater
4. dewater PROPOSED USE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other auger

6. LITHOLOGIC LOG

8. WELL CONSTRUCTION

| Material | Water Strata | From | To | Thick-ness |
|-----------------|--------------|------|----|------------|
| sandy gravel | | 0 | 11 | 11 |
| cemented congl. | | 11 | 12 | 1 |
| brown clay | | 12 | 14 | 2 |
| cemented congl. | | 14 | 24 | 10 |
| brown clay | | 24 | 30 | 6 |

| Depth Drilled | Feet | Depth Cased | Feet |
|---------------|------|-------------|------|
| 30 | | 30 | |

HOLE DIAMETER (BIT SIZE)

| From | To |
|------|----|
| 24 | 30 |
| 0 | 30 |

INCHES FEET FEET FEET

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 14 | 36.71 | .250 | +1 | 30 |

RECEIVED
NOV 19 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Perforations:
Type perforation machine slot
Size perforation 1/4" x 2" x 8 rows of 16
From 15 feet to 30 feet
From 15 feet to 30 feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
From 0 feet to 30 feet

9. WATER LEVEL
Static water level 11 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allen Drilling, Inc.
Contractor
Address 4847 So. Valley View Blvd.
Las Vegas, Nev. 89103

7. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift
G.P.M. Draw Down (Feet Below Static) Time (Hours)

Nevada contractor's license number 0018917
issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301

Signed [Signature] by drilling party printing actual drilling on site or contractor
Date 11-13-92