

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 66429  
 Permit No. 212  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12118

1. OWNER TEMPLE TRUST  
 MAILING ADDRESS 3017 W. CHARLESTON STE 90 ADDRESS AT WELL LOCATION 10th STREET AUTO, LAS VEGAS NV 89102  
 2. LOCATION NE 1/4 SW 1/4 Sec 34 T 20 N R 61 E CLARK County  
 PERMIT NO. MO-2337 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT & GRAVEL FILL		0	1 1/2	1 1/2
SILTY CLAY		1 1/2	3	1 1/2
CALICHE		3	5	2
CLAYEY SILT		5	14	9
SILTY CLAY		14	18	4
CLAYEY SAND		18	25	7

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 0 Feet 25 Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.154</u>	<u>0</u>	<u>25</u>

Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 0.020  
 From 5 feet to 25 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-2 1/2-4' BENTONITE  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 4 feet to 25 feet

RECEIVED  
 NOV 16 1993  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started OCTOBER 11, 1993  
 Date completed OCTOBER 11, 1993

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level feet below land surface  
 Artesian flow G.P.M. P.S.I.  
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name THOMAS HIGHT Contractor  
 Address 4670 SOUTH POLARIS AVE  
LAS VEGAS, NV 89103 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869  
 Signed Tom Hight  
 By driller performing actual drilling on site or contractor  
 Date 11-11-93