

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 66442

Permit No. 212

Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25738

1. OWNER Southland ADDRESS AT WELL LOCATION 2416 E Stewart
MAILING ADDRESS Las Vegas, Nevada

2. LOCATION NE 1/4 SE 1/4 Sec 35 T 20 N 8 R 6 E Clark County

PERMIT NO. 7-11 store # 20379 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
FILL - AK Agg. Base SAND		0	2	2
SILTY CLAY		2	8	6
SILTY SAND	X	8	10	2
SILTY CLAY w/ small sand layers		10	20	10

8. WELL CONSTRUCTION

Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	From	To	Feet
<u>8 1/2</u>		0		<u>20</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>Sch 40 PVC</u>	<u>0</u>	<u>20</u>

Perforations:

Type perforation Factory Slots

Size perforation .010

From 5 feet to 20 feet

From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement

Depth of Seal 3 Cement Grout

Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No

From 4 feet to 20 feet

9. WATER LEVEL

Static water level 8.3 feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature Cool °F Quality Contaminated

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Terracon Consultants Waster Contractor

Address 3711 Regulus Dr. Contractor

L.V. NV. 89102

Nevada contractor's license number issued by the State Contractor's Board _____

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-18441

Signed Thomas W. Beall Jr.
By driller performing actual drilling on site or contractor

Date 7-10-94

Date started 7-6 1994

Date completed 7-6 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED

JAN 12 1995

Div. of Water Resources
Branch Office - Las Vegas, NV