WELL MW-2

In Book

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66449
Permit No.
Basin 212

NOTICE OF INTENT NO. 9656

1. OWNER H AND W AUTO
MAILING ADDRESS 3021 BUILDERS AVE
LAS VEGAS, NV 89108

ADDRESS AT WELL LOCATION 3021 BUILDERS AVE
LAS VEGAS, NV 89108

2. LOCATION SW ¼ SE ¼ Sec. 36 T. 20 N/S R. 61 E/W CLARK County
PERMIT NO. MO-2122 (Issued by Water Resources) | LOT 4, BLOCK 3 (Parcel No.) | EAST PARK INDUSTRIAL UNIT NO. 2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVELLY CLEAN FILL MATERIAL		0	2	2
SILTY CLAY WITH FINE SAND		2	7.5	5.5
MEDIUM DENSE GRAVELLY SAND		7.5	15.5	8.0

RECEIVED
MAY 25 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started FEB 2, 1992
Date completed FEB 2, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 15.5 Feet Depth Cased 15.5 Feet

HOLE DIAMETER (BIT SIZE)

		From		To
6 Inches	0 Feet	15.5 Feet		
Inches	Feet	Feet		
Inches	Feet	Feet		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SHD 40	0	5.2

Perforations:
Type perforation MACHINE SLOT SHD 40 PVC
Size perforation 0.020 INCH
From 5.2 feet to 15.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0 – 2 FT
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 4.0 feet to 15.5 feet

9. WATER LEVEL
Static water level 8.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name (Contractor)
Address (Contractor)

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1338

Signed Michael Briner
By driller performing actual drilling on site or contractor

Date 5-25-93

I

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627