WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 66455
Permit No.
Basin

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6247

1. OWNER CAL NEV PIPELINE CO.
MAILING ADDRESS P.O. BOX 6346
SAN BERNARDINO CA 92412

ADDRESS AT WELL LOCATION CAL NEV
5049 NORTH SLOAN LANE
LAS VEGAS NV. 89115

2. LOCATION SE ¼ SE ¼ Sec. 33 T. 19 N/S R. 62 E. CLARK County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ monitoring ~~Test~~ ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY SILT		0'	6'	6'
CALICHE		6'	8'	2'
SANDY SILT		8'	15'	7'
CALICHE		15'	19'	4'
SANDY SILT		19'	39'	20'
SILTY CLAY		39'	41	2'
SANDY SILT		41'	58'	17'
CLAYEY SILT		58'	79	21'
SILTY CLAY		79'	95'	16'
CLAYEY SILT		95'	120'	25'

RECEIVED
JAN 07 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 12-19-90, 19
Date completed 12-19, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6" inches Total depth 115 feet
inches
inches
Casing record 0 - 115
Weight per foot 0.70 lbs Thickness Sch 40 PVC

Diameter	From	To
2" ~~6~~ inches	0 feet	115 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement grout
Depth of seal 59 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 63 feet to 116 feet

Perforations:
Type perforation FACTORY-SLOTTED SCREEN
Size perforation 0.020 inch
From 75 feet to 115 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 88.84 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson / Converse Consultants (Contractor)
Address 4670 S. Polaris Ave, LV, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed [signature] (By driller performing actual drilling on site or contractor)
Date

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627