


PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



Log No. _____
Well No. _____
NOTICE OF PATENT NO. 14408

1. OWNER TEXACO
MAILING ADDRESS Universal City Plaza
Universal City CA 91668
2. LOCATION SE 1/4 SE 1/4 Sec 33 T 19 N 8R 62 E
PERMIT NO. MO-2544 Issued by Water Resources

Parcel No. _____

Subdivision Name _____

3. WORK PERFORMED
 New Well
 Replace
 Deepen
 Abandon
 Recondition
 Other
 Domestic
 Municipal/Industrial
 Irrigation
 Test
 Monitor
 Stock
 Cable
 Rotary
 RVC
 Air
 Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty sand		0	5'	
Caliche		5'	10'	
clay silt		10'	20'	
silty sand		20'	25'	
silty clay		25'	35'	
partially cemented		35'	50'	
silty clay		50'	60'	
clayey silt		60'	70'	
caliche hard		70'	72'	
sandy clay		72'	80'	
water		93.5		
sandy silt		80'	105'	
clayey silt		105'	115'	
sandy silt		115'	120'	

RECEIVED
APR 21 1995
DIVISION OF WATER RESOURCES
P.O. BOX 10000 LAS VEGAS, NV

8. WELL CONSTRUCTION
 Depth Drilled: 120' Feet
 HOLE DIAMETER (BIT SIZE)
 From: 8 Inches
 To: 120' Feet
 From: 0 Feet
 To: 120' Feet
 From: _____ Feet
 To: _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.218	0	120'

Perforations:
 Type perforation Factory slot
 Size perforation 0.030 feet to 120' feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 0 to 68' / 103' 48'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 68' feet to 120' feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thomas R. High
 Contractor R. High
 Address 4670 So. Repar's Ave
 City LV State NV Zip 89103

Contractor's License No. _____
 Nevada contractor's license number issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller's license number M-1869

Signed Thomas R. High
 Date Apr. 1 17 1995
 By driller performing actual drilling on site or contractor

7. TEST METHOD: Bailor Pump Air Lift
 G.P.M. _____ Draw Down (Feet Below Static) _____ Time (Hours) _____
 Date started Feb 27 1995
 Date completed Feb 28 1995