WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66472
Permit No.
Basin

NOTICE OF INTENT NO. 12112

1. OWNER CAL NEV PIPELINE CO
MAILING ADDRESS P.O. BOX 6346 SAN BERNARDINO, CA 92412
ADDRESS AT WELL LOCATION 5049 N. SLOAN LANE, NORTH LAS VEGAS NV

2. LOCATION SW ¼ NW ¼ Sec 34 T 19 N/S R 62 E CLARK County
PERMIT NO. MO-2258A Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE PRODUCT REC.
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY CLAY		0	8	8
CLAYEY SILT		8	20	12
CALICHE		20	21	1
CLAYEY SILT		21	40	19
SILTY CLAY		40	65	25
CALICHE		65	66	1
SILTY CLAY		66	68	2
GRAVELLY CLAY		68	71	3
SILTY CLAY		71	130	59

RECEIVED
DEC 16 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started NOVEMBER 11, 19 93
Date completed NOVEMBER 12, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 129 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	130

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	129

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 79 feet to 114 feet
From 124 feet to 126.5 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-75/117-122' BENT
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 75-117 feet to AND 122-130' feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH
Contractor
Address 4670 SO POLARIS AVE
Contractor
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1869
Signed Thomas R. High
by driller performing actual drilling on site or contractor
Date 12/14/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627