WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66474
Permit No.
Basin

NOTICE OF INTENT NO. 12112

1. OWNER CAL NEV PIPELINE Co
MAILING ADDRESS P.O. BOX 6346
SAN BERNARDINO, CA 92412
ADDRESS AT WELL LOCATION 5017 N. SLOAN LANE
NORTH LAS VEGAS, NV

2. LOCATION SW ¼ NW ¼ Sec. 34 T. 19 N/S R. 62 E. CLARK County
PERMIT NO. MD-2258A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE PRODUCT REC
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY CLAY		0	6	6
CALICHE		6	7	1
CLAYEY SILT		7	20	13
CALICHE		20	21	1
CLAYEY SILT		21	35	14
CALICHE		35	36	1
SANDY CLAY		36	63	27
CALICHE		63	64	1
SILTY CLAY		64	130	66

RECEIVED
NOV 16 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started NOVEMBER 3, 19 93
Date completed NOVEMBER 4, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 129 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	130

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	19	0.237	0	129

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 24 feet to 114 feet
From 124 feet to 126 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-75/117-122 BENTONITE
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 75-117 AND feet to 122-130 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WILLIAM MAXWELL (Contractor)
Address 4670 SO. POLARIS AVE (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589T-1
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-11-93

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627