

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13919

1. OWNER Southland Corp. c/o SECOR ADDRESS AT WELL LOCATION 7-ELEVEN #19588
 MAILING ADDRESS 3021 S. Valley View St. E. 109 6515 SOUTH EASTERN
LV. NV. 89102
 2. LOCATION NE 1/4 NE 1/4 Sec. 2 T 22 N 0 R 01 E Clark County
 PERMIT NO. MO-2516 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill poorly graded		0'	4'	
Partly Graded sand		4'	9'	
trace silt damp		9'	15'	
water				
Clay with silt		15'	20'	
Partly graded sand		20'	24'	

2" PVC was installed
 water sample was
 taken, then PVC
 was pulled and
 holes was grouted
 to surface.

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
8"	0'	24'		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0'	24'

Perforations:
 Type perforation Factory slot
 Size perforation 0.20
 From 7.9' feet to 24' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thomas High Contractor
 Address 4670 So. Pebaris Ave Contractor
Las Vegas NV. 89103
 Nevada contractor's license number _____ issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
 Signed Tom High
 By driller performing actual drilling on site or contractor
 Date 1-3-95

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 JAN 04 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV