



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **MO 221**

1. OWNER City of Henderson ADDRESS AT WELL LOCATION WR-5  
 MAILING ADDRESS 1240 Water Street Henderson NV 89015

2. LOCATION NW 1/4 NE 1/4 Sec. 4 T. 22 N. OR. 62 E Clark County

PERMIT NO. MO 221 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
AC-Base		0	1	1
Gravelly Sand		1	3	2
Cemented Sand and Gravel		3	4	1
Gypsum		4	5	1
Gravelly Sand w/ Gypsum		5	8	3
Cemented Sand and Gravel		8	13	5
Silty Clay		13	15	2

8. WELL CONSTRUCTION  
 Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 0 Feet 15 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>Sch 40</u>	<u>0</u>	<u>15</u>

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation .010  
 From 5 feet to 15 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 3  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 4 feet to 15 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 4/14 1994  
 Date completed 4/16 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Name Western Technologies Inc.  
 Address 3611 West Tompkins Avenue Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board NA  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 701761

Signed [Signature]  
 By driller performing actual drilling of site or contractor  
 Date 4-25-94