WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66523
Permit No.
Basin 212

NOTICE OF INTENT NO. 12137

1. OWNER ROYAL KENFIELD COUNTRY CLUB
MAILING ADDRESS 1 KENFIELD CLUB DRIVE HENDERSON NV
ADDRESS AT WELL LOCATION 1 KENFIELD CLUB DRIVE

2. LOCATION SW ¼ SW ¼ Sec. 5 T. 22 N/S R. 62 E. CLARK County
PERMIT NO. MD-2371 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-1
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SILTY SAND | | 0 | 4 | 4 |
| CLAYEY SAND | | 4 | 8 | 4 |
| SANDY CLAY | | 8 | 12 | 4 |
| CLAYEY SAND | | 12 | 20 | 8 |

Date started DEC 27, 19 93
Date completed DEC 27, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 8 | 0 | 20 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | 0.64 | 0.154 | 0 | 20 |
| | | | | |

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-1'/1-3' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 20 feet

9. WATER LEVEL
Static water level 10.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON
Contractor
Address 4670 SO POLARIS AVE
Contractor
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed
By driller performing actual drilling on site or contractor
Date JAN 13, 1994

RECEIVED JAN 14 1994 Div. of Water Resources Las Vegas, NV

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627