WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

inBook

OFFICE USE ONLY
Log No. 66541
Permit
Basin

NOTICE OF INTENT NO. 12090

1. OWNER CAL NEV PIPELINE CO.
MAILING ADDRESS P.O. BOX 6346
SAN BERNARDINO, CA 92412

ADDRESS AT WELL LOCATION 5049 N. SLOAN LANE
NORTH LAS VEGAS, NV

2. LOCATION SW ¼ NW ¼ Sec. 34 T. 19 N/S R. 62 E. CLARK County
PERMIT NO. MO-2304 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	2	2
CLAYEY SAND		2	8.5	6.5
SANDY CLAY		8.5	10	1.5
CLAYEY GRAVEL		10	12	2
CLAYEY SILT		12	16	4
SILTY CLAY		16	21	5
CALICHE		21	21.5	0.5
CLAY		21.5	31.5	10
CLAYEY SILT		31.5	35	3.5
CALICHE		35	35.5	0.5
SANDY CLAY		35.5	40	4.5
CALICHE		40	41.5	1.5
SILTY CLAY w/GRAVEL		41.5	62	20.5
CALICHE		62	63.5	1.5
SILTY CLAY		63.5	68	4.5
CLAY GRAVEL		68	71	3
SILTY CLAY		71	130	59

Date started AUGUST 12, 19 93
Date completed AUGUST 14, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 129 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	0 Feet	130 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	129

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 125 feet to 127 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-120'/120-122' BENT
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 122 feet to 130 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of ~~my knowledge~~.
Name RICHARD LE BLANC (Contractor)
Address 4670 So. POLARIS AVE (Contractor)
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed R Le Blanc (By driller performing actual drilling on site or contractor)
Date 11-1-93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627