WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 66542
Permit No.
Basin

NOTICE OF INTENT NO. 12090

1. OWNER CAL NEV PIPELINE CO.
MAILING ADDRESS P.O. 6346
SAN BERNARDINO, CA 92412

ADDRESS AT WELL LOCATION 5049 N. SLOAN LANE
NORTH LAS VEGAS, NV

2. LOCATION SW ¼ NW ¼ Sec. 34 T. 19 N/S R. 62 E. CLARK County
PERMIT NO. MO-2304 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	1.5	1.5
SILTY CLAY		1.5	5.5	4
CALICHE		5.5	6	0.5
SILTY CLAY		6	21	15
CALICHE		21	21.5	0.5
CLAY		21.5	32	10.5
CLAYEY SILT		32	34.5	2.5
CLAY		34.5	40	5.5
CALICHE		40	42	2
GRAVELLY CLAY		42	51	9
CLAYEY SILT		51	54	3
SILTY CLAY		54	63	9
CALICHE		63	64	1
SILTY CLAY		64	68	4
CLAYEY GRAVEL		68	71	3
CLAY		71	85	14
SILTY CLAY		85	130	45

Date started AUGUST 16, 19 93
Date completed AUGUST 16, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 129 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	130 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	129

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 125 feet to 127 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-120' / 120-123' BENT.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 123 feet to 130 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of ~~my knowledge~~.
Name RICHARD LE BLANC (Contractor)
Address 4670 SO. POLARIS AVE (Contractor)
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed R Le Blanc (By driller performing actual drilling on site or contractor)
Date 11-1-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627