

Log No. 66567
 Permit No. 212
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF PATENT NO. 14291

1. OWNER DANES SIMONE ADDRESS AT WELL LOCATION Nellis TT-B SITE SD-30
 MAILING ADDRESS 4220 S. Maryland Ave #103 LV NV 89119
 2. LOCATION N2 1/4 NW 1/4 Sec. 3 T. 20 N. R. 62 E. Clark County
 PERMIT NO. MD-2509 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other N.C.M.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>CLAY</u>		<u>0</u>	<u>55</u>	
<u>C. SILT</u>		<u>35</u>	<u>39</u>	
<u>CLAY</u>		<u>39</u>	<u>56</u>	
<u>C. SILT</u>		<u>56</u>	<u>62</u>	
<u>CLAY W/ SAND</u>				
<u>FINES</u>		<u>62</u>	<u>100</u>	
<u>G. SANDS</u>		<u>100</u>	<u>105</u>	

8. WELL CONSTRUCTION
 Depth Drilled 105 Feet Depth Cased 100 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 105 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.5</u>	<u>PVC</u>	<u>SCH 40</u>	<u>0</u>	<u>70</u>

Perforations:
 Type perforation SLOT HOLE SCREEN
 Size perforation .020
 From 70 feet to 100 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 62 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 64 feet to 105 feet

9. WATER LEVEL
 Static water level 7.6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 11-14 1995
 Date completed 11-15 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wesley G. Zimmerman Contractor
 Address 4301 S. Maryland Ave #21 Contractor
LV NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 0035839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 111910
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 2-24-95