

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10567

1. OWNER 360° Communications ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 8725 W. Higgins Rd 118 South 10th Street
Chicago, IL 60631

2. LOCATION NE 1/4 SE 1/4 Sec 34 T 20 S R 61 E CLARK County
 PERMIT NO. NA 139-34-712-036 Parcel No. _____
 Issued by Water Resources Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG MLW-1

Material	Water Strata	From	To	Thick-ness
Fill - 3" AC / base		0	.5	
SILTY CLAY		.5	2.5	
SANDY CLAY - w/ gravel		2.5	5.5	
CALICHE		5.5	6.5	
SANDY CLAY - w/ gravel		6.5	7.5	
CALICHE		7.5	9.5	
SILTY SAND		9.5	11.5	
SANDY CLAY	Y	11.5	14	
SILTY SAND	Y	14	15.5	
SANDY CLAY - w/ gravel	Y	15.5	20	
CALICHE	Y	20	23 23	
SANDY CLAY	Y	23	25	

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 1/2 Inches To 0 Feet 25 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>25</u>

Perforations:
 Type perforation slotted screen
 Size perforation .010 inch
 From 10 feet to 25 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 8 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 8 feet to 25 feet

9. WATER LEVEL
 Static water level 11.94 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 6/16, 1997
 Date completed 6/16, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Tim Aten c/o Terracon Consultants Contractor
 Address 4343 S. Polar's Ave
Las Vegas, NV 89103 Contractor
 Nevada contractor's license number _____
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2017
 Signed Samuel A. Kutarni
 By driller performing actual drilling on site or contractor
 Date 7-1-97